



FIRE SUPPRESSION PIPING LEGEND





STAIR #8 SPRINKLER RISER DETAIL

SCALE: NONE

FIRE SUPPRESSION GENERAL NOTES:

- A. LOCATIONS AND ROUTING OF EXISTING PIPING, DUCTWORK AND EQUIPMENT IS PRESUMED FROM EXISTING DRAWINGS. MECHANICAL CONTRACTOR SHALL FIELD VERIFY ALL PRIOR TO COMMENCEMENT OF CONSTRUCTION. NOTIFY ENGINEER OF ANY CONDITIONS WHICH WILL NOT PERMIT THE WORK TO BE PERFORMED AS INDICATED ON THESE DRAWINGS.
- B. COORDINATE ALL SHUT-DOWNS OF EXISTING SYSTEMS WITH OWNER A MINIMUM OF TEN WORKING DAYS IN ADVANCE.
- C. PRIOR TO INSTALLATION, VERIFY PRECISE LOCATION OF NEW WALL MOUNTED DEVICES WITH OWNER AND ARCHITECT. REFER TO ARCHITECTURAL REFLECTED CEILING PLAN FOR PRECISE LOCATION OF CEILING MOUNTED DEVICES.
- D. PROVIDE ADEQUATE SERVICE CLEARANCE FOR ALL EQUIPMENT. REFER TO INSTRUCTIONS FROM THE EQUIPMENT MANUFACTURER.
- E. NEW PIPING SHALL NOT BE ROUTED ABOVE ELECTRICAL PANELS. REFER TO ELECTRICAL DRAWINGS FOR LOCATION OF PANELS.
- F. THE FIRE SUPPRESSION CONTRACTOR SHALL PROVIDE DETAILED DESIGN OF THE SPRINKLER
- SYSTEM. REFER TO SPECIFICATIONS. G. UNLESS OTHERWISE NOTED NEW SPRINKLERS SHALL BE AS FOLLOWS: G.1. AREAS WITH CEILINGS: RECESSED CONCEALED STYLE WITH COVER PLATES. G.2. EXPOSED STRUCTURE: UPRIGHT OR PENDENT TYPE.
- G.3. OPERATING ROOMS: RECESSED CONCEALED STYLE WITH COVER PLATES.
- H. ALL SPRINKLERS FURNISHED AS PART OF THIS PROJECT SHALL HAVE COVER PLATES WITH THE SAME SHAPE AND SIZE. COLOR SHALL BE SELECTED BY ARCHITECT.
- SHALL BE DETERMINED BY FIRE PROTECTION CONTRACTOR, BASED ON HYDRAULIC CALCULATIONS. . CONTRACTOR IS RESPONSIBLE TO SUBMIT THEIR FIRE PROTECTION SHOP DRAWINGS TO OWNERS

THE FIRE PROTECTION SYSTEM IS PERFORMANCE SPECIFIED. ALL SPRINKLER PIPE SIZES

- INSURANCE UNDERWRITER AND LOCAL FIRE MARSHAL AND OBTAIN APPROVAL PRIOR TO STARTING WORK.
- K. PROVIDE SUPPLEMENTAL DRAINS AS NECESSARY TO PROVIDE 100% SYSTEM DRAINAGE. LOCATE DRAINS ABOVE ACCESSIBLE CEILINGS.
- L. REFER TO ARCHITECTURAL PLANS FOR EXACT PHASING REQUIREMENTS.
- M. REFER TO SPECIFICATIONS FOR FIRE SUPPRESSION HAZARD OCCUPANCY CLASSIFICATIONS.
- N. SPRINKLER PIPING SHALL BE A MINIMUM OF ONE INCH.
- O. UNLESS OTHERWISE STATED ON DRAWINGS OR IN THE SPECIFICATIONS, ALL SPRINKLER HEADS
- SHALL BE QUICK RESPONSE.
- P. ALL HEADS SHALL BE UL LISTED AND FM APPROVED.
- Q. ALL SPRINKLER HEADS LOCATED IN CEILING TILES SHALL BE LOCATED IN CENTER OF THE CEILING TILE.

R. ALL SPRINKLER ZONES SHALL MATCH SMOKE COMPARTMENTS. REFER TO ARCHITECTURAL

PLANS FOR INFORMATION ON SMOKE COMPARTMENTS, SMOKE PARTITIONS AND FIRE BARRIERS. S. CONTRACTOR SHALL REMOVE AND REPLACE CEILING TILES AND GRID AS REQUIRED TO COMPLETE DEMOLITION AND NEW WORK IN AREAS OUTSIDE OF RENOVATION PROJECT. CONTRACTOR SHALL BE RESPONSIBLE FOR REPLACING ANY TILES OR GRID DAMAGED DUE TO

PROJECT COORDINATION NOTES:

- A. THIS PROJECT CONSISTS OF MULTIPLE TRADES OF WORK PERFORMED WITHIN AN EXISTING BUILDING AND A BUILDING ADDITION, ALL OF WHICH ALLOWS VERY LITTLE PERMISSIBLE RANGE OF VARIATION. THE CONTRACTOR SHALL TAKE CAREFUL CONSIDERATION WITH THE COORDINATION AND INSTALLATION OF THE MULTITUDE OF NEW SYSTEMS WHILE ALSO ACCOMMODATING ANY EXISTING SYSTEMS TO REMAIN.
- B. THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING ALL TRADES ASSOCIATED WITH THIS PROJECT AND ISSUING COORDINATION PLANS PRIOR TO COMMENCEMENT OF EACH PHASE OF CONSTRUCTION.
- C. THE COORDINATION DRAWINGS SHALL ILLUSTRATE ALL SYSTEMS IN PLACE. NO EXCEPTIONS! THE CONTRACTOR SHALL SHOW ALL NECESSARY OFFSETS, TRANSITIONS, ETC. AS REQUIRED IN ORDER TO ACCOMMODATE CONDITIONS IDENTIFIED IN THE FIELD.
- D. IF CONFLICTS ARE IDENTIFIED DURING THE DEVELOPMENT OF COORDINATION PLANS, THE CONTRACTOR SHALL NOTIFY THE VA COTR, ARCHITECT, AND/OR ENGINEER OF ANY CONDITIONS WHICH WILL NOT PERMIT THE WORK TO BE PERFORMED AS INDICATED ON THE
- E. A COMPLETED SET OF COORDINATION PLANS ISSUED FOR REVIEW SHALL CONFIRM THAT THE CONTRACTOR FULLY UNDERSTANDS THE PROJECT CONSTRAINTS AND ALL KNOWN CONFLICTS HAVE BEEN ADDRESSED.

LEAD SHIELDING NOTE

S1. REFER TO ARCHITECTURAL PLANS FOR DESIGNATED WALLS IN THE PROJECT AREA TO BE LINED WITH LEAD SHIELDING BY THE CONTRACTOR. FOR EXISTING MECHANICAL DEVICES THAT ARE INDICATED TO REMAIN, THE MECHANICAL CONTRACTOR SHALL REMOVE AND RE-INSTALL OR RELOCATE THESE DEVICES. THE GC SHALL PROVIDE NEW LEAD SHIELDING FOR ALL SUCH DEVICES. FOR NEW MECHANICAL DEVICES, THE GC SHALL PROVIDE ALL LEAD SHIELDING FOR EACH DEVICE. THE MECHANICAL CONTRACTOR SHALL COORDINATE ALL SUCH WORK WITH THE GENERAL CONTRACTOR, AND SHALL ASSIST THE GENERAL CONTRACTOR IN THE PERFORMANCE OF THIS WORK. IN ANY CASE, ALL PLUMBING DEVICES, HVAC DEVICES, FIRE PROTECTION DEVICES, ETC. INSTALLED IN THESE WALLS SHALL BE SHIELDED WITH

FULLY SPRINKLERED

Office of

Facilities

Management

Bid Issue 01/17/14

Date

THE THE THE THE THE THE

Revisions:

VA FORM 08- 6231, OCT 1978

FREDRICK, FREDRICK & HELLER ENGINEERS, INC. 672 EAST ROYALTON ROAD BROADVIEW HTS., OHIO 44147 TEL. (440) 546-9696 FAX: (440) 546-9699

CONSULTANTS:







DESIGN AND CONSTRUCTION DOCUMENTS AS INSTRUMENTS OF SERVICE ARE GIVEN IN CONFIDENCE AND REMAIN THE PROPERTY OF PERSPECTUS ARCHITECTURE. THE USE OF THIS DESIGN AND THESE CONSTRUCTION DOCUMENTS FOR PURPOSES OTHER THAN THE SPECIFIC PROJECT NAMED HEREIN IS STRICTLY PROHIBITED WITHOUT THE EXPRESSED WRITTEN CONSENT OF PERSPECTUS ARCHITECTURE.

FIRE PROTECTION LEGEND, DETAILS, AND GENERAL NOTES Approved: Project Director

1-17-2014

EXPAND AND RENOVATE NUCLEAR MEDICINE AND RADIOLOGY VAMC - WADE PARK

Checked


BMW


Building Number Drawing Number 1-FP-0 Drawn DAD


Project Number


541-14-101

Department of Veterans Affairs









A. LOCATIONS AND ROUTING OF EXISTING PIPING, DUCTWORK AND EQUIPMENT IS PRESUMED

PLUMBING GENERAL NOTES:

- FROM EXISTING DRAWINGS. MECHANICAL CONTRACTOR SHALL FIELD VERIFY ALL PRIOR TO COMMENCEMENT OF CONSTRUCTION. NOTIFY ENGINEER OF ANY CONDITIONS WHICH WILL NOT PERMIT THE WORK TO BE PERFORMED AS INDICATED ON THESE DRAWINGS.
- B. COORDINATE ALL SHUT-DOWNS OF EXISTING MECHANICAL SYSTEMS WITH OWNER A MINIMUM OF TEN (10) WORKING DAYS IN ADVANCE.
- C. PRIOR TO INSTALLATION, VERIFY PRECISE LOCATION OF NEW WALL MOUNTED DEVICES WITH
- OWNER AND ARCHITECT. D. PROVIDE ADEQUATE SERVICE CLEARANCE FOR ALL MECHANICAL EQUIPMENT. REFER TO

DRAWINGS FOR LOCATION OF PANELS.


- INSTRUCTIONS FROM THE EQUIPMENT MANUFACTURER. E. NEW PIPING SHALL NOT BE ROUTED ABOVE ELECTRICAL PANELS. REFER TO ELECTRICAL
- F. WHERE EXISTING FIXTURES ARE TO BE REMOVED, REMOVE ALL ASSOCIATED BRANCH PIPING WHICH IS NOT TO BE REUSED. REMOVE PIPING TO MAINS AND CAP REMAINING PIPES.

MEDICAL GAS GENERAL NOTES:

- PROVIDE MEDICAL GAS PIPING SYSTEMS AND PIPE LABELS COMPLYING WITH REQUIREMENTS OF NFPA 99 "STANDARD FOR HEALTH CARE FACILITIES".
- INSTALLATION AND CERTIFICATION SHALL COMPLY WITH ASSE/ANSI SERIES 6000, "PROFESSIONAL QUALIFICATIONS STANDARDS FOR MEDICAL GAS SYSTEMS INSTALLERS, INSPECTORS AND VERIFIERS".
- 3. PROVIDE COMPATIBLE ACCESSORIES, TUBE, FITTING, AND VALVES FOR EACH SYSTEM. A. OUTLET / INLET STYLE:
- MEDICAL GAS TUBE, FITTINGS AND JOINTS: PRE-CLEANED AND SEALED COPPER TUBE: ASTM B 88, TYPE K OR TYPE L, WATER TUBE, SEAMLESS, DRAWN TEMPER, CLEANED FOR MEDICAL GAS USE, PURGED, AND WITH ENDS SEALED.
- MEDICAL SYSTEM ACCESSORIES: PROVIDE THE MEDICAL GAS SYSTEM ACCESSORIES FROM MANUFACTURER OF EXISTING ACCESSORIES, COMPATIBLE WITH EXISTING SYSTEMS.
- D. SERVICE OUTLETS: INCLUDE BRASS VALVE AND BODY BLOCK WITH SEALS IN ROUGH-IN AND FINISHING ASSEMBLIES, STEEL OUTLET BOX AND COVER PLATE; 3/8 INCH TYPE K OR L COPPER TUBE BRAZED TO VALVE; AND PRESSURE OUTLETS WITH AUTOMATIC SECONDARY SERVICE VALVE TO PREVENT GAS FLOW WHEN PRIMARY VALVE IS REMOVED. DISS COUPLING SHALL BE INDEXED TO PREVENT INTERCHANGE BETWEEN SERVICES, CONSTRUCTED TO PERMIT ONE HANDED CONNECTION AND REMOVAL OF EQUIPMENT WITH POSITIVE LOCKING RING WHICH RETAINS EQUIPMENT STEM IN VALVE DURING USE. OUTLET/INLET TYPE OF CONNECTION SHALL BE COORDINATED WITH THE OWNER PRIOR TO ORDERING EQUIPMENT.
- INSTALL LABELING ON VALVES, VALVE BOX COVERS, AND ALARM PANELS IN ACCORDANCE WITH REQUIREMENTS OF NFPA 99 AND VA STANDARDS. CAPTIONS AND COLOR CODING: PER THE REQUIREMENTS OF NFPA 99 AND VA STANDARDS.
- 5. LOCATIONS AND ROUTING OF EXISTING PIPING, DUCTWORK AND EQUIPMENT IS PRESUMED FROM EXISTING DRAWINGS. MECHANICAL CONTRACTOR SHALL FIELD VERIFY ALL PRIOR TO COMMENCEMENT OF CONSTRUCTION. NOTIFY ENGINEER OF ANY CONDITIONS WHICH WILL NOT PERMIT THE WORK TO BE PERFORMED AS INDICATED ON THESE DRAWINGS.
- COORDINATE ALL SHUT-DOWNS IF EXISTING MEDICAL GAS AND VACUUM SYSTEMS WITH OWNER A MINIMUM OF TEN WORKING DAYS IN ADVANCE.
- PRIOR TO INSTALLATION, VERIFY PRECISE LOCATION OF NEW WALL MOUNTED DEVICES WITH OWNER AND ARCHITECT.
- PROVIDE ADEQUATE SERVICE CLEARANCE FOR ALL EQUIPMENT. REFER TO INSTRUCTIONS FROM THE EQUIPMENT MANUFACTURER.
- 9. NEW PIPING SHALL NOT BE ROUTED ABOVE ELECTRICAL PANELS. REFER TO ELECTRICAL DRAWINGS FOR LOCATION OF PANELS.
- 10. WHERE EXISTING FIXTURES ARE TO BE REMOVED, REMOVE ALL ASSOCIATED BRANCH PIPING WHICH IS NOT TO BE REUSED. REMOVE PIPING TO MAINS AND CAP REMAINING PIPES.
- 11. MEDICAL GAS MATERIALS, EQUIPMENT AND INSTALLATION SHALL COMPLY WITH NFPA 99, HEALTH CARE FACILITIES", LATEST EDITION. INSTALLATION PERSONNEL SHALL BE QUALIFIED IN ACCORDANCE WITH ASSE SERIES 6000, "PROFESSIONAL QUALIFICATIONS FOR MEDICAL GAS SYSTEMS INSTALLERS, INSPECTORS AND VERIFIERS".

LEAD SHIELDING NOTE

S1. REFER TO ARCHITECTURAL PLANS FOR DESIGNATED WALLS IN THE PROJECT AREA TO BE LINED WITH LEAD SHIELDING BY THE CONTRACTOR. FOR EXISTING MECHANICAL DEVICES THAT ARE INDICATED TO REMAIN, THE MECHANICAL CONTRACTOR SHALL REMOVE AND RE-INSTALL OR RELOCATE THESE DEVICES. THE GC SHALL PROVIDE NEW LEAD SHIELDING FOR ALL SUCH DEVICES. FOR NEW MECHANICAL DEVICES, THE GC SHALL PROVIDE ALL LEAD SHIELDING FOR EACH DEVICE. THE MECHANICAL CONTRACTOR SHALL COORDINATE ALL SUCH WORK WITH THE GENERAL CONTRACTOR, AND SHALL ASSIST THE GENERAL CONTRACTOR IN THE PERFORMANCE OF THIS WORK. IN ANY CASE, ALL PLUMBING DEVICES, HVAC DEVICES, FIRE PROTECTION DEVICES, ETC. INSTALLED IN THESE WALLS SHALL BE SHIELDED WITH LEAD.



CLINIC SERVICE SINK ROUGH-IN DETAIL

Date

PLUMBING SYMBOLS:

REFERENCE TO CODED NOTE EQUIPMENT OR FIXTURE MARK C.T.E. CONNECT TO EXISTING PLUMBING CONTRACTOR GENERAL CONTRACTOR NATURAL GAS

—ST— STORM WATER SANITARY WASTE —SAN— PLUMBING VENT

TEMPERED WATER ——CW—— DOMESTIC COLD WATER SUPPLY _____ DOMESTIC HOT WATER SUPPLY ___________ DOMESTIC HOT WATER RETURN _____

DOMESTIC HIGH TEMPERATURE HOT WATER ------—HTHW(140°F)—

EXISTING TO BE REMOVED — — — —

RAIN WATER CONDUCTOR FLOOR DRAIN EXISTING TO REMAIN

ISOLATION VALVE

CHECK VALVE MOTORIZED CONTROL VALVE

UNION REDUCER

STRAINER BALANCING VALVE


PIPE GUIDE PIPE EXPANSION ANCHOR

FLEXIBLE METAL EXPANSION LOOP ASSEMBLY

NEW WORK CONNECTION POINT

LIMIT OF DEMOLITION

MEDICAL GAS SYMBOLS:



BRANCH CONNECTION ISOLATION VALVE

LOCKABLE VALVE (INLINE/SERVICE) MEDICAL GAS PRESSURE SENSOR

MEDICAL GAS CONNECTION WITH OUTLET/INLET

MEDICAL GAS VACUUM SLIDE MEDICAL GAS ALARM PANEL

MEDICAL GAS VALVE BOX ACCESS SIDE OF VALVE BOX OR ALARM PANEL

MEDICAL ALARM PANEL

MEDICAL VALVE BOX

PROJECT COORDINATION NOTES:

- A. THIS PROJECT CONSISTS OF MULTIPLE TRADES OF WORK PERFORMED WITHIN AN EXISTING BUILDING, ALL OF WHICH ALLOWS VERY LITTLE PERMISSIBLE RANGE OF VARIATION. THE CONTRACTOR SHALL TAKE CAREFUL CONSIDERATION WITH THE COORDINATION AND INSTALLATION OF THE MULTITUDE OF NEW SYSTEMS WHILE ALSO ACCOMMODATING ANY EXISTING SYSTEMS TO REMAIN.
- B. THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING ALL TRADES ASSOCIATED WITH THIS PROJECT AND ISSUING COORDINATION PLANS PRIOR TO COMMENCEMENT OF EACH PHASE OF CONSTRUCTION.
- C. THE COORDINATION DRAWINGS SHALL ILLUSTRATE ALL SYSTEMS IN PLACE. NO EXCEPTIONS! THE CONTRACTOR SHALL SHOW ALL NECESSARY OFFSETS, TRANSITIONS, ETC. AS REQUIRED IN ORDER TO ACCOMMODATE CONDITIONS IDENTIFIED IN THE FIELD.
- D. IF CONFLICTS ARE IDENTIFIED DURING THE DEVELOPMENT OF COORDINATION PLANS, THE CONTRACTOR SHALL NOTIFY THE VA COTR, ARCHITECT, AND/OR ENGINEER OF ANY CONDITIONS WHICH WILL NOT PERMIT THE WORK TO BE PERFORMED AS INDICATED ON THE PROJECT PLANS.
- E. A COMPLETED SET OF COORDINATION PLANS ISSUED FOR REVIEW SHALL CONFIRM THAT THE CONTRACTOR FULLY UNDERSTANDS THE PROJECT CONSTRAINTS AND ALL KNOWN CONFLICTS HAVE BEEN ADDRESSED.

MEDICAL VALVE BOX SCHEDULE

| VALVE | ١ | WALL WIDTH | | | | | | |
|-----------------------------------|------|------------|------|----------|--|--|--|--|
| BOX | OX | MV | MA | REQUIRED | | | | |
| MVB-1 | 1/2" | 3/4" | 1/2" | 27.9" | | | | |
| MVB-2 | 1/2" | 3/4" | 1/2" | 27.9" | | | | |
| MVB-3 | 1/2" | 3/4" | 1/2" | 27.9" | | | | |
| MVB-4 | 1/2" | 3/4" | 1/2" | 27.9" | | | | |
| MVB-5 | 1/2" | 3/4" | 1/2" | 27.9" | | | | |
| NOTES: (1) LABEL PER VA STANDARDS | | | | | | | | |

MEDICAL GAS AREA ALARM PANEL SCHEDULE


| ALARM VALVE BOX PANEL SERVED | | WALL WIDTH REQUIRED | NOTES | | | | |
|---|------------------|------------------------|-------|--|--|--|--|
| MAP-1 | MVB-1 THRU MVB-5 | 16" | _ | | | | |
| ı | _ | ı | _ | | | | |
| NOTES: (1) PROVIDE REMOTE SENSORS AND WIRING FROM SENSORS TO ALARM PANEL. (2) LABEL PER VA STANDARDS. | | | | | | | |

(3) TIE ALARM PANEL ALARMS INTO BMS.

PLUMBING FIXTURE CONNECTION SCHEDULE

| <u> </u> | VECTION . | 3011LI | | | | |
|----------|---------------------------------------|------------------|------|--------|--------|--|
| MARK | FIXTURE | BRANCH PIPE SIZE | | | | |
| | | CW | HW | WASTE | VENT | |
| P-103 | WATER CLOSET WALL HUNG | 1-1/2" | _ | 4" | 2" | |
| P-414 | LAVATORY WALL HUNG | 3/4" | 3/4" | 1-1/2" | 1-1/2" | |
| P-418 | LAVATORY WALL HUNG | 3/4" | 3/4" | 1-1/2" | 1-1/2" | |
| P-505 | CLINIC SINK WALL HUNG | 1-1/2" | 3/4" | 4" | 2 | |
| P-528 | STAINLESS STEEL DROP IN SINK | 3/4" | 3/4" | 1-1/2" | 1-1/2" | |
| P-530 | STAINLESS STEEL UNDERMOUNT SINK | 3/4" | 3/4" | 1-1/2" | 1-1/2" | |
| P-531 | STAINLESS STEEL UNDERMOUNT SINK | 3/4" | 3/4" | 1-1/2" | 1-1/2" | |
| P-532 | INTEGRAL STAINLESS STEEL SINK | 3/4" | 3/4" | 1-1/2" | 1-1/2" | |
| P-609 | ELECTRIC WATER COOLER | 3/4" | - | 1-1/2" | 1-1/2" | |
| P-707 | EMERGENCY SHOWER/EYE WASH | 3/4" | 3/4" | _ | _ | |
| P-810 | MIXING VALVE | 3/4" | 3/4" | - | - | |
| FD-A | FLOOR DRAIN | - | - | 4" | 2" | |
| FD-C | FLOOR DRAIN | - | - | 4" | 2" | |
| | - | | | | | |

PROVIDE INSULATION PROTECTION FOR ALL ADA LAVATORIES. P-532 IS INTEGRAL TO COUNTERTOP. REFER TO ARCHITECTURAL PLANS FOR ADDITIONAL INFORMATION. REFER TO SPECIFICATIONS FOR FAUCET AND PLUMBING



36" (900 MM) MAX.

– 1 5/8" (43 MM) 12 GAGE

CHANNEL OR 2"x2"x1/4"

MASONRY

PARTITION

[152mm]

INSULATED

PIPE OR

(50x50x8 MM) ANGLE


SPACING ON EACH CHANNEL


TYPICAL PIPE HANGERS NOT TO SCALE

TRAPEZE HANGER FOR UP

TO 1000 LB. (453 KG) UNIFORM LOAD

1" (25 MM) MAX.——






PIPE OR DUCT - PIPE SLEEVE DRYWALL PARTITION < FIRESTOP WHERE SPECIFIED MATERIAL -- PARTITION SUPPORT - FLOOR ANCHOR ROD FOR PARTITION OR CHASE PENETRATION NEW CONSTRUCTION FIRESTOP MATERIAL 3/4" [19mm] APPROVED FIRESTOP APPLICABLE TO PENETRATIONS OF INSULATION WITH ALL FIRE RATED MEMBRANES, IN VAPOR BARRIER ACCORDANCE WITH NFPA 101. REFER TO SPECIFICATIONS SECTION FLOOR OR DECK PENETRATION FOR FIRE STOPPING SYSTEMS. PIPE/DUCT PENETRATION OF FIRE/SMOKE BARRIERS

3/4" [19mm] APPROVED

VAPOR BARRIER

INSULATED

FIRESTOP INSULATION WITH



TYPICAL METHOD OF SECURING HANGER RODS IN CONCRETE SLABS AND BEAMS

TO OUTLETS CEILING DOWNSTREAM "SOURCE SIDE" "PATIENT SIDE" **DETAIL NOTES:** REFER TO ARCHITECTURAL PLANS FOR VALVE BOX AND ALARM PANEL LOCATIONS. SEE ARCHITECTURAL ELEVATIONS FOR MOUNTING HEIGHTS OF VALVE BOXES AND ALARM PANELS. DETAIL SHOWN IS TYPICAL FOR - MEDICAL GAS NON-ANESTHETIZING LOCATIONS. REFER ALARM PANEL TO FLOOR PLANS FOR QUANTITIES AND TYPES OF GASES AT EACH VALVE BOX/ALARM LOCATION. ZONE VALVE BOX -" S " DENOTES REMOTE LINE PRESSURE SENSOR WITH DISS DEMAND CHECK 4. REFER TO FLOOR PLANS FOR SIZES AND ROUTING OF MEDICAL GAS PIPING.


TYPICAL MEDICAL GAS VALVE BOX DETAIL

FULLY SPRINKLERED

CONSULTANTS: Bid Issue 01/17/14

FREDRICK, FREDRICK & HELLER ENGINEERS, INC. 672 EAST ROYALTON ROAD BROADVIEW HTS., OHIO 44147 TEL. (440) 546-9696 FAX: (440) 546-9699

2217 East 9th Street, Suite 350 Cleveland OH 44115-1257 216-875-0100/ (F) 216-875-0111 barberhoffman.com BARBER & HOFFMAN, INC. Consulting Engineers



ARCHITECT: 13212 Shaker Square Suite 204 Cleveland, Ohio 44120

DESIGN AND CONSTRUCTION DOCUMENTS A NSTRUMENTS OF SERVICE ARE GIVEN IN CONFIDENCE AND REMAIN THE PROPERTY OF PERSPECTUS ARCHITECTURE. THE USE OF THIS DESIGN AND THESE CONSTRUCTION DOCUMENTS FOR PURPOSES OTHER THAN THE SPECIFIC PROJECT NAMED HEREIN IS STRICTLY PROHIBITED WITHOUT THE EXPRESSED WRITTEN CONSENT OF PERSPECTUS ARCHITECTURE.

PLUMBING LEGEND, SCHEDULES, DETAILS, AND NOTES

Drawing Title

roject Number 541-14-101 **EXPAND AND RENOVATE** NUCLEAR MEDICINE AND Building Number **RADIOLOGY** Drawing Number Checked DAD

Office of Facilities Management

VA FORM 08- 6231, OCT 1978

Revisions:

P. 216.752.1800 F.216.752.3833 Approved: Project Director

VAMC - WADE PARK 1-17-2014 BMW

Department of Veterans Affairs

